## RESOLUTION NO. 1039

A RESOLUTION ADOPTING LOCAL PRETREATMENT DISCHARGE LIMITS FOR PENN TOWNSHIP DISCHARGERS TO THE HANOVER REGIONAL WASTEWATER TREATMENT FACILITY.

WHEREAS, on August 3, 1983, the Board of Commissioners of Penn Township, York County, Pennsylvania (Township) entered into agreement with the Borough of Hanover (Borough), to transport and treat sewage originating within certain areas of each other's political subdivision, and

WHEREAS, the General Pretreatment Regulations (40CFR, Part 403) allows the Borough to establish specific pollutant limitations on users of its publicly owned treatment works, and

WHEREAS, users of the sanitary sewer system who are located in Penn Township, and whose sanitary sewer discharge terminates at the Hanover Area Wastewater Treatment Facility, are required to comply with the specified pollutant limitations established by the Borough, and

WHEREAS, the local discharge limits may be detailed in the user's wastewater discharge permit following approval of said limits by the U.S. Environmental Protection Agency.

NOW, THEREFORE, BE IT RESOLVED, that the Township of Penn hereby adopts the following allowable discharge limits for users of the Hanover Regional Wastewater Treatment Facility:

Pollutant <sup>1</sup>	Current Local Limit mg/L	Proposed Local Limit <sup>2</sup> , <sup>3</sup> mg/L
Antimony	0.14	0.28
Arsenic	0.12	0.10
BOD		1,180
Cadmium	0.01	0.01
Chloroform	0.45	0.28
Chromium	3.30	3.30
Chromium, Hexavale	ent 0.38	0.47
Copper	1.00	1.00
Cyanide	0.30	0.14
Lead	0.13	0.45
Mercury	0.0080	0.0085
Molybdenum	0.28	0.16
Nickel	1.00	1.00
Selenium	0.14	0.11
Silver	0.24	0.39
Trichloroethylene	0.29	0.24
Zinc	0.67	0.56

## Notes:

- (1) All Local Limits enforced as Maximum Daily limits.
- (2) As Will Be Adopted by the Borough in Ordinance No. 2373 on October 23, 2024.

(3) As accepted by USEPA on June 28, 2024.

RESOLVED AND ENACTED this 21st day of October 2024.

Board of Commissioners of Penn Township

By:\_

Mark/R. Elksnis, President

Attest:

Laura Klinefelter, Secretary